



सत्यमेव जयते

Government Of West Bengal
Office Of The Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo no.: FES/MSD/248/2017

Date: 06-08-2023

From:
Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

To: SUBHADRA PAL PTTI
Rub by Aurobinda Educational Welfare Turst, Vill-Jamuar, Po-Senda Jamuar, Ps-RaghunathGanj, Dist-
Murshidabad, W.B, Pin-742235

Sub: Renewal of Fire Safety Certificate for An Existing construction of G+3 storied building under group Educational at the premises mark Name: SUBHADRA PAL PTTI, Organized By Rishi Aurobinda Educational Welfare Trust, Vill-Jamuar, P.O-Senda Jamuar, P.S-Raghunathganj, Dist-Murshidabad, W.B, Pin-742235.

This is in reference to your application no. 0125191230900107 dated 25-07-2023 regarding the Renewal of Fire Safety Certificate for An Existing construction of G+3 storied building under group Educational at the premises mark Name: SUBHADRA PAL PTTI, Organized By Rishi Aurobinda Educational Welfare Trust, Vill-Jamuar, P.O-Senda Jamuar, P.S-Raghunathganj, Dist-Murshidabad, W.B, Pin-742235.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Always main gate is to be made free and should engage a person for maintenance of the gate.
2. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
3. If any inflammable liquids/materials/gases etc. is storied beyond the specified quantity, license shall be obtained from the appropriate authority.
4. All extinguishers should be tested and refilled when required and certificate is to be pasted in the body of the extinguisher.
5. Always underground and overhead reservoir should be filled up with water.

- 6.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly Maintained.
- 7.Existing Electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
- 8.The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
- 9.The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
- 10.Cooking arrangement is strictly prohibited in the building.
- 11.Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 12..Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
- 13.Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above mentioned system.
- 14.The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 15.Fire Safety Certificate shall be renewed in 3(Three) years comprising safety installation are in working condition.
- 16.Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this FSC will be treated as cancelled.

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

Memo No.: FES/MSD/248/2017